

VOC Content Test Certificate

Wednesday, 6th April 2016

Manufacturer: Intex International. 115 McKellar Way Epping Victoria, Australia 3076 Sample

Description: Intex MegaGrip®

Date Tested: October 2008 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in

Various Materials as referenced by South Coast Air Quality Management District

Test Data: (SCAQMD) Rule 1168

Specification	Megagrip
Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	
Dry wall and panel adhesive 50 grams per Litre as VOC content coating	45 grams per Litre as VOC content per coating
Specification	Megagrip
Green Building Council of Australia Green Star Office Design V3 IEQ-13	
Dry wall and panel adhesive 50 grams per Litre as VOC content coating	45 grams per Litre as VOC content per coating



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

CV160406